

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/6/2017
Report No.: 539723 - Lead Water
Project: Schalick High School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6268846 **Location:** Kitchen-2 Tub-Sink Faucet **Result(ppb):** 5.90
Client No.: 1-SHS-SF-K2T

Lab No.: 6268847 **Location:** Kitchen-Kettle-Faucet Outlet **Result(ppb):** 13.2
Client No.: 2-SHS-FO-K

Lab No.: 6268848 **Location:** Kitchen-Steamer Unit **Result(ppb):** 4.90
Client No.: 3-SHS-ST-K

Lab No.: 6268849 **Location:** Hall At 303 (Left)-Water Cooler **Result(ppb):** <2.00
Client No.: 4-SHS-WC-H303-L

Lab No.: 6268850 **Location:** Hall At 303 (Right)-Water Cooler **Result(ppb):** <2.00
Client No.: 5-SHS-WC-H303-R

Lab No.: 6268851 **Location:** Hall At 215 (Left)-Water Cooler **Result(ppb):** <2.00
Client No.: 6-SHS-WC-H215-L

Lab No.: 6268852 **Location:** Hall At 215 (Right)-Water Cooler **Result(ppb):** <2.00
Client No.: 7-SHS-WC-H215-R

Lab No.: 6268853 **Location:** 213-Special Education-Sink Faucet **Result(ppb):** 4.40
Client No.: 8-SHS-SF-213

Lab No.: 6268854 **Location:** Library Office-603-Sink Faucet **Result(ppb):** 4.30
Client No.: 9-SHS-SF-603

Lab No.: 6268855 **Location:** Trainer's Room-311-Ice Machine **Result(ppb):** <2.00
Client No.: 10-SHS-IM-TRAIN

Lab No.: 6268856 **Location:** Trainer's Room-311-Sink Faucet **Result(ppb):** 425
Client No.: 11-SHS-SF-TRAIN

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/22/2017

Date Analyzed: 07/06/2017

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/6/2017
Report No.: 539723 - Lead Water
Project: Schalick High School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6268857 **Location:** Hall At Faculty (Left)-Water Cooler **Result(ppb):** <2.00
Client No.:
12-SHS-WC-HFACULTY-L

Lab No.: 6268858 **Location:** Hall At Faculty (Right)-Water Cooler **Result(ppb):** <2.00
Client No.:
13-SHS-WC-HFACULTY-R

Lab No.: 6268859 **Location:** Faculty-Sink Faucet **Result(ppb):** 5.40
Client No.: 14-SHS-SF-FACULTY

Lab No.: 6268860 **Location:** Main Office-Sink Faucet **Result(ppb):** 6.30
Client No.: 15-SHS-SF-MAINO

Lab No.: 6268861 **Location:** Hall At 203 (Left)-Water Cooler **Result(ppb):** <2.00
Client No.: 16-SHS-WC-H203-L

Lab No.: 6268862 **Location:** Hall At 203 (Right)-Water Cooler **Result(ppb):** <2.00
Client No.: 17-SHS-WC-H203-R

Lab No.: 6268863 **Location:** Hall At Guidance (Left)-Water Cooler **Result(ppb):** <2.00
Client No.: 18-SHS-WC-HGUIDE-L

Lab No.: 6268864 **Location:** Hall At Guidance (Right)-Water Cooler **Result(ppb):** 2.20
Client No.: 19-SHS-WC-HGUIDE-R

Lab No.: 6268865 **Location:** Nurse's Office-Sink Faucet **Result(ppb):** 5.80
Client No.: 20-SHS-SF-NURSEO

Lab No.: 6268866 **Location:** Nurse's Exam-Sink Faucet **Result(ppb):** 33.7
Client No.: 21-SHS-SF-EXAM

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/22/2017

Date Analyzed: 07/06/2017

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/6/2017
Report No.: 539723 - Lead Water
Project: Schalick High School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6268867
Client No.: 22-SHS-BLANK

Location: Blank

Result(ppb): <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/22/2017

Date Analyzed: 07/06/2017

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/6/2017
Report No.: 539723 - Lead Water
Project: Schalick High School
Project No.: 17-421

Client: TTI379

Appendix to Analytical Report:

Customer Contact: TTI Reports

Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com

iATL Office Manager: cdavis@iatl.com

iATL Account Representative: Shirley Clark

Sample Login Notes: See Batch Sheet Attached

Sample Matrix: Water

Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 6/30/2017
Report No.: 539422 - Lead Water
Project: "Old Consortium LIDW"; Pittsgrove Middle School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6266992 **Location:** 601-Sink Faucet **Result(ppb):** 2.30
Client No.: 13-PMS-SF-601

Lab No.: 6266993 **Location:** Hall At 601 (Left)-Water Cooler **Result(ppb):** 2.20
Client No.: 14-PMS-WC-H601-L

Lab No.: 6266994 **Location:** Hall At 601 (Right)-Water Cooler **Result(ppb):** <2.00
Client No.: 15-PMS-WC-H601-R

Lab No.: 6266995 **Location:** 606-Sink Faucet **Result(ppb):** 2.10
Client No.: 16-PMS-SF-606

Lab No.: 6266996 **Location:** Main Office-Sink Bubbler **Result(ppb):** 7.70
Client No.: 17-PMS-SB-MAINO

Lab No.: 6266997 **Location:** Main Office-Sink Faucet **Result(ppb):** 2.80
Client No.: 18-PMS-SF-MAINO

Lab No.: 6266998 **Location:** Nurse's Office-Sink Bubbler **Result(ppb):** 6.80
Client No.: 19-PMS-SB-NURSEO

Lab No.: 6266999 **Location:** Nurse's Office-Sink Faucet **Result(ppb):** <2.00
Client No.: 20-PMS-SF-NURSEO

Lab No.: 6267000 **Location:** Nurse's Exam-Sink Bubbler **Result(ppb):** 115
Client No.: 21-PMS-SB-EXAM

Lab No.: 6267001 **Location:** Nurse's Exam-Sink Faucet **Result(ppb):** 7.00
Client No.: 22-PMS-SF-EXAM

Lab No.: 6267002 **Location:** 501-Sink Faucet **Result(ppb):** 3.20
Client No.: 23-PMS-SF-501

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/21/2017

Date Analyzed: 06/30/2017

Signature:

Analyst: Mark Stewart

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 6/30/2017
Report No.: 539422 - Lead Water
Project: "Old Consortium LIDW"; Pittsgrove Middle School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6267003 **Location:** Hall At 506 (Left)-Water Cooler **Result(ppb):** <2.00
Client No.: 24-PMS-WC-H506-L

Lab No.: 6267004 **Location:** Hall At 506 (Right)-Water Cooler **Result(ppb):** <2.00
Client No.: 25-PMS-WC-506-R

Lab No.: 6267005 **Location:** 506-Sink Faucet **Result(ppb):** <2.00
Client No.: 26-PMS-SF-506

Lab No.: 6267006 **Location:** 107-Sink Faucet **Result(ppb):** 8.90
Client No.: 27-PMS-SF-107

Lab No.: 6267007 **Location:** 105-Music-Sink Bubbler **Result(ppb):** <2.00
Client No.: 28-PMS-SB-105

Lab No.: 6267008 **Location:** 105-Music-Sink Faucet **Result(ppb):** 13.1
Client No.: 29-PMS-SF-105

Lab No.: 6267009 **Location:** Cafe/Stage-Sink Faucet **Result(ppb):** 10.3
Client No.: 30-PMS-SF-STAGE

Lab No.: 6267010 **Location:** Faculty-Sink Faucet **Result(ppb):** <2.00
Client No.: 31-PMS-SF-FACULTY


Lab No.: 6267011 **Location:** Kitchen-1 Tub-Sink Faucet **Result(ppb):** <2.00
Client No.: 32-PMS-SF-K

Lab No.: 6267012 **Location:** Kitchen-Steamer Unit **Result(ppb):** 12.9
Client No.: 33-PMS-ST-K

Lab No.: 6267013 **Location:** Hall At 709 (Left)-Water Cooler **Result(ppb):** 2.40
Client No.: 34-PMS-WC-H709-L

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/21/2017
Date Analyzed: 06/30/2017
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.

1253 North Church St.

Moorestown NJ 08057

Report Date: 6/30/2017

Report No.: 539422 - Lead Water

Project: "Old Consortium LIDW"; Pittsgrove Middle School

Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6267014

Location: Hall At 709 (Right)-Water Cooler

Result(ppb): <2.00

Client No.: 35-PMS-WC-H709-R

Lab No.: 6267015

Location: Blank

Result(ppb): 2.00

Client No.: 37-PMS-Blank

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 6/21/2017

Date Analyzed: 06/30/2017

Signature:

Analyst: Mark Stewart

Approved By:



Frank E. Ehrenfeld, III

Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 6/30/2017
Report No.: 539422 - Lead Water
Project: "Old Consortium LIDW"; Pittsgrove Middle School
Project No.: 17-421

Client: TTI379

Appendix to Analytical Report:

Customer Contact: TTI Reports

Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com

iATL Office Manager: cdavis@iatl.com

iATL Account Representative: Shirley Clark

Sample Login Notes: See Batch Sheet Attached

Sample Matrix: Water

Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 6/30/2017
Report No.: 539424 - Lead Water
Project: "Old Consortium LIDW"; Olivet Elementary
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6266508 **Location:** Faculty-Sink Faucet **Result(ppb):** 6.30
Client No.: 1-OES-SF-FACULTY

Lab No.: 6266509 **Location:** 33-Sink Faucet **Result(ppb):** 5.00
Client No.: 2-OES-SF-33

Lab No.: 6266510 **Location:** Kitchen-1 Tub Prep Table-Sink Faucet **Result(ppb):** 6.00
Client No.: 3-OES-SF-K

Lab No.: 6266511 **Location:** Cafe-Water Cooler **Result(ppb):** 3.50
Client No.: 4-OES-WC-CAFE

Lab No.: 6266512 **Location:** 30-Music Room-Sink Bubbler **Result(ppb):** <2.00
Client No.: 5-OES-SB-30

Lab No.: 6266513 **Location:** 29-Sink Bubbler **Result(ppb):** 13.7
Client No.: 6-OES-SB-29

Lab No.: 6266514 **Location:** Art Room-Sink Bubbler **Result(ppb):** 35.2
Client No.: 7-OES-SB-ART

Lab No.: 6266515 **Location:** Hall At 26-Water Cooler **Result(ppb):** <2.00
Client No.: 9-OES-WC-H26

Lab No.: 6266516 **Location:** 26-Sink Bubbler **Result(ppb):** <2.00
Client No.: 10-OES-SB-26

Lab No.: 6266517 **Location:** 26-Sink Faucet **Result(ppb):** <2.00
Client No.: 11-OES-SF-26

Lab No.: 6266518 **Location:** Hall At Copy Room-Water Cooler **Result(ppb):** 2.40
Client No.: 12-OES-WC-HCOPY

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/21/2017

Date Analyzed: 06/30/2017

Signature:

Analyst: Mark Stewart

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 6/30/2017
Report No.: 539424 - Lead Water
Project: "Old Consortium LIDW"; Olivet Elementary
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6266519 **Location:** Main Office-Water Cooler **Result(ppb):** 3.50
Client No.: 13-OES-WC-MAINO

Lab No.: 6266520 **Location:** Nurse's Office-Sink Faucet **Result(ppb):** 13.8
Client No.: 14-OES-SF-NURSE

Lab No.: 6266521 **Location:** Hall At Ramp Near Gym-Water Cooler **Result(ppb):** <2.00
Client No.: 15-OES-WC-HRAMP

Lab No.: 6266522 **Location:** Hall At Gym-Water Cooler **Result(ppb):** <2.00
Client No.: 16-OES-WC-HGYM

Lab No.: 6266523 **Location:** Hall At 11-Water Cooler **Result(ppb):** <2.00
Client No.: 17-OES-WC-H11

Lab No.: 6266524 **Location:** Hall At 3-Water Cooler **Result(ppb):** 3.90
Client No.: 18-OES-WC-H3

Lab No.: 6266525 **Location:** Blank **Result(ppb):** <2.00
Client No.: Blank

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 6/21/2017

Date Analyzed: 06/30/2017

Signature:

Analyst: Mark Stewart

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Client: TTI379

Report Date: 6/30/2017
Report No.: 539424 - Lead Water
Project: "Old Consortium LIDW"; Olivet Elementary
Project No.: 17-421

Appendix to Analytical Report:

Customer Contact: TTI Reports

Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com

iATL Office Manager: cdavis@iatl.com

iATL Account Representative: Shirley Clark

Sample Login Notes: See Batch Sheet Attached

Sample Matrix: Water

Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 6/30/2017
Report No.: 539423 - Lead Water
Project: "Old Consortium Pricing LIDW" Elmer Elementary School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6266526 **Location:** 1-Sink Bubbler **Result(ppb):** 3.60
Client No.: 1-EES-SB-1

Lab No.: 6266527 **Location:** 5-Sink Bubbler **Result(ppb):** 9.40
Client No.: 2-EES-SB-5

Lab No.: 6266528 **Location:** 6-Sink Bubbler **Result(ppb):** 34.6
Client No.: 3-EES-SB-6

Lab No.: 6266529 **Location:** 7-Sink Bubbler **Result(ppb):** 4.50
Client No.: 4-EES-SB-7

Lab No.: 6266530 **Location:** Hall At 8-Water Cooler **Result(ppb):** <2.00
Client No.: 5-EES-WC-H8

Lab No.: 6266531 **Location:** 8-Sink Bubbler **Result(ppb):** 4.20
Client No.: 6-EES-SB-8

Lab No.: 6266532 **Location:** 9-Sink Bubbler **Result(ppb):** 5.70
Client No.: 7-EES-SB-9

Lab No.: 6266533 **Location:** 10-Sink Bubbler **Result(ppb):** 6.00
Client No.: 8-EES-SB-10

Lab No.: 6266534 **Location:** 11-Sink Bubbler **Result(ppb):** 5.70
Client No.: 9-EES-SB-11

Lab No.: 6266535 **Location:** Hall At 12-Water Cooler **Result(ppb):** <2.00
Client No.: 10-EES-WC-H12

Lab No.: 6266536 **Location:** 12-Sink Bubbler **Result(ppb):** 4.70
Client No.: 11-EES-SB-12

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/21/2017

Date Analyzed: 06/30/2017

Signature:

Analyst: Mark Stewart

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 6/30/2017
Report No.: 539423 - Lead Water
Project: "Old Consortium Pricing LIDW" Elmer Elementary School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6266537
Client No.: 12-EES-SB-13

Location: 13-Sink Bubbler

Result(ppb): 3.80

Lab No.: 6266538
Client No.: 13-EES-SF-K

Location: Kitchen-Sink Faucet

Result(ppb): 2.80

Lab No.: 6266539
Client No.: 15-EES-SF-NURSE

Location: Nurse's Office-Sink Faucet

Result(ppb): <2.00

Lab No.: 6266540
Client No.: 16-EES-SF-FACULTY

Location: Faculty-Sink Faucet

Result(ppb): <2.00

Lab No.: 6266541
Client No.: 17-EES-SB-16

Location: 16-Sink Bubbler

Result(ppb): 4.20

Lab No.: 6266542
Client No.: 18-EES-SB-15

Location: 15-Sink Bubbler

Result(ppb): 5.00

Lab No.: 6266543
Client No.: BLANK

Location: Blank

Result(ppb): <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/21/2017

Date Analyzed: 06/30/2017

Signature:

Analyst:

Mark Stewart

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 6/30/2017
Report No.: 539423 - Lead Water
Project: "Old Consortium Pricing LIDW" Elmer
Elementary School
Project No.: 17-421

Client: TTI379

Appendix to Analytical Report:

Customer Contact: TTI Reports

Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com

iATL Office Manager: cdavis@iatl.com

iATL Account Representative: Shirley Clark

Sample Login Notes: See Batch Sheet Attached

Sample Matrix: Water

Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/6/2017
Report No.: 539421 - Lead Water
Project: "Old Consortium LIDW"; Norma Elementary School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6266953

Location: Hall At Boiler Room-Water Cooler

Result(ppb): 12.5

Client No.: 1-NES-WC-HBOILER

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/21/2017

Date Analyzed: 07/06/2017

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/6/2017
Report No.: 539421 - Lead Water
Project: "Old Consortium LIDW"; Norma Elementary School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6266954 **Location:** Faculty-Sink Faucet **Result(ppb):** <2.00
Client No.: 2-NES-SF-FACULTY

Lab No.: 6266955 **Location:** Cafe-2 Tub-Sink Faucet **Result(ppb):** <2.00
Client No.: 3-NES-SF-CAFE.2

Lab No.: 6266956 **Location:** Cafe-Sink Faucet **Result(ppb):** <2.00
Client No.: 4-NES-SF-CAFE.1

Lab No.: 6266957 **Location:** 8-Sink Bubbler **Result(ppb):** 2.40
Client No.: 5-NES-SB-8

Lab No.: 6266958 **Location:** 8-Sink Faucet **Result(ppb):** <2.00
Client No.: 6-NES-SF-8

Lab No.: 6266959 **Location:** 9-Sink Faucet **Result(ppb):** <2.00
Client No.: 7-NES-SF-9

Lab No.: 6266960 **Location:** 6-Sink Faucet **Result(ppb):** <2.00
Client No.: 8-NES-SF-6

Lab No.: 6266961 **Location:** 4-Sink Bubbler **Result(ppb):** 4.60
Client No.: 9-NES-SB-4

Lab No.: 6266962 **Location:** 4-Sink Faucet **Result(ppb):** <2.00
Client No.: 10-NES-SF-4

Lab No.: 6266963 **Location:** Hall At Nurse's Office-Water Cooler **Result(ppb):** <2.00
Client No.: 11-NES-WC-HNURSE

Lab No.: 6266964 **Location:** Nurse's Office-Sink Faucet **Result(ppb):** <2.00
Client No.: 12-NES-SF-NURSE

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/21/2017

Date Analyzed: 07/05/2017

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/6/2017
Report No.: 539421 - Lead Water
Project: "Old Consortium LIDW"; Norma Elementary School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6266965 **Location:** Hall At 3-Drinking Water Bubbler **Result(ppb):** <2.00
Client No.: 13-NES-DW-H5

Lab No.: 6266966 **Location:** Hall At 5-Drinking Water Bubbler **Result(ppb):** <2.00
Client No.: 14-NES-WC-H3

Lab No.: 6266967 **Location:** 5-Sink Bubbler **Result(ppb):** <2.00
Client No.: 15-NES-SB-5

Lab No.: 6266968 **Location:** 5-Sink Faucet **Result(ppb):** <2.00
Client No.: 16-NES-SF-5

Lab No.: 6266969 **Location:** 3-Sink Bubbler **Result(ppb):** <2.00
Client No.: 17-NES-SB-3

Lab No.: 6266970 **Location:** 3-Sink Faucet **Result(ppb):** <2.00
Client No.: 18-NES-SF-3

Lab No.: 6266971 **Location:** 2-Drinking Water Bubbler **Result(ppb):** <2.00
Client No.: 19-NES-DW-2

Lab No.: 6266972 **Location:** 2-Sink Faucet **Result(ppb):** <2.00
Client No.: 20-NES-SF-2


Lab No.: 6266973 **Location:** 1-Drinking Water Bubbler **Result(ppb):** <2.00
Client No.: 21-NES-DW-1

Lab No.: 6266974 **Location:** 1-Sink Faucet **Result(ppb):** <2.00
Client No.: 22-NES-SF-1

Lab No.: 6266975 **Location:** NC 1-Sink Faucet **Result(ppb):** <2.00
Client No.: 23-NES-SF-NC1

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/21/2017
Date Analyzed: 07/05/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/6/2017
Report No.: 539421 - Lead Water
Project: "Old Consortium LIDW"; Norma Elementary School
Project No.: 17-421

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6266976
Client No.:24-NES-WC-HNC3

Location:Hall At NC 3-Water Cooler

Result(ppb):<2.00

Lab No.:6266977
Client No.:25-NES-SF-NC4

Location:NC 4-Sink Faucet

Result(ppb):<2.00

Lab No.:6266978
Client No.:26-NES-SF-NC3

Location:NC 3-Sink Faucet

Result(ppb):<2.00

Lab No.:6266979
Client No.:27-NES-SF-NC2

Location:NC 2-Sink Faucet

Result(ppb):33.5

Lab No.:6266980
Client No.:28-NES-Blank

Location:Blank

Result(ppb):<2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/21/2017

Date Analyzed: 07/05/2017

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/6/2017
Report No.: 539421 - Lead Water
Project: "Old Consortium LIDW"; Norma Elementary School
Project No.: 17-421

Client: TTI379

Appendix to Analytical Report:

Customer Contact: TTI Reports

Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com

iATL Office Manager: cdavis@iatl.com

iATL Account Representative: Shirley Clark

Sample Login Notes: See Batch Sheet Attached

Sample Matrix: Water

Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.